

**Important Information you need to read. Do not include this page with the CCR you provide to customers.**

TCEQ provides the CCR Generator as a tool for systems to begin creating their CCR, you must add information to this draft report to make it complete. Instructions: The following pages require manual entry before distribution to your customers and submission to TCEQ. Source water information, water system contact information, and a phone number must be provided with the Spanish statement (below water system contact). If your system purchases water and is on a limited sampling schedule the wholesale provider water quality data must be included. Disinfectant Residual table - the name of the disinfectant(s) (ex: free chlorine), the annual average, the range of samples for the reported year, and unit of measure (ex: mg/L). For a guided video on completing your CCR, checkout <https://www.youtube.com/watch?v=ksTOgC3tV0g>. All other information provided by the CCR generator must be included. It is the responsibility of the water system to provide the CCR to customers and TCEQ by July 1, and ensure

the CCR meets all requirements. For more detailed information and instruction on the CCR, visit <https://www.tceq.texas.gov/drinkingwater/ccr>.

## 2023 Consumer Confidence Report for Public Water System CITY OF KENEDY

This is your water quality report for January 1 to December 31, 2023

CITY OF KENEDY provides ground water from [Gulf Coast Aquifer] located in [Karnes County].

For more information regarding this report contact:

Name Johnny Rodriguez (public Works)

Phone 830-299-1774

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (830) 583 - 2230.

### Definitions and Abbreviations

#### Definitions and Abbreviations

The following tables contain scientific terms and measures, some of which may require explanation.

#### Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

#### Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

#### Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

#### Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

#### Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

#### Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

#### Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

#### Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

#### MFL

million fibers per liter (a measure of asbestos)

#### mrem:

millirems per year (a measure of radiation absorbed by the body)

#### na:

not applicable.

#### NTU

nephelometric turbidity units (a measure of turbidity)

#### pCi/L

picocuries per liter (a measure of radioactivity)

## Definitions and Abbreviations

ppb:	micrograms per liter or parts per billion
ppm:	milligrams per liter or parts per million
ppq	parts per quadrillion, or picograms per liter (pg/L)
ppt	parts per trillion, or nanograms per liter (ng/L)
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Information about Source Water

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact [Johnny Rodriguez] [830-299-1774]

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	04/13/2021	1.3	1.3	0.108	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	04/13/2021	0	15	1.5	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

### 2023 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2023	2	0 - 2.1	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

\*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

<b>Total Trihalomethanes (TTHM)</b>	2023	11	1.2 - 11.2	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
-------------------------------------	------	----	------------	-----------------------	----	-----	---	--

\*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Arsenic</b>	2023	8	5.1 - 9.9	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.

While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

<b>Barium</b>	2023	0.0287	0.0287 - 0.0287	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
<b>Fluoride</b>	2023	0.38	0.38 - 0.38	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
<b>Nitrate [measured as Nitrogen]</b>	2023	1	1.11 - 1.11	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
<b>Selenium</b>	2023	3.5	3.5 - 3.5	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Beta/photon emitters</b>	02/22/2022	10.8	10.8 - 10.8	0	50	pCi/L*	N	Decay of natural and man-made deposits.

\*EPA considers 50 pCi/L to be the level of concern for beta particles.

<b>Gross alpha excluding radon and uranium</b>	02/22/2022	4	4 - 4	0	15	pCi/L	N	Erosion of natural deposits.
<b>Uranium</b>	02/22/2022	8.6	8.6 - 8.6	0	30	ug/l	N	Erosion of natural deposits.

### Disinfectant Residual

A blank disinfectant residual table has been added to the CCR template, you will need to add data to the fields. Your data can be taken off the Disinfectant Level Quarterly Operating Reports (DLQOR).

## Disinfectant Residual

A blank disinfectant residual table has been added to the CCR template, you will need to add data to the fields. Your data can be taken off the Disinfectant Level Quarterly Operating Reports (DLQOR).

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chlorine	2023	1.89	0.50 – 2.51	4	4	ppm	N	Water additive used to control microbes.

## Violations

### Consumer Confidence Rule

The Consumer Confidence Rule requires community water systems to prepare and provide to their customers annual consumer confidence reports on the quality of the water delivered by the systems.

Violation Type	Violation Begin	Violation End	Violation Explanation
CCR REPORT	07/01/2023	12/29/2023	We failed to provide to you, our drinking water customers, an annual report that informs you about the quality of our drinking water and characterizes the risks from exposure to contaminants detected in our drinking water.

### Lead and Copper Rule

The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.

Violation Type	Violation Begin	Violation End	Violation Explanation
FOLLOW-UP OR ROUTINE TAP M/R (LCR)	07/01/2023	2023	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.
WATER QUALITY PARAMETER M/R (LCR)	01/01/2023	06/30/2023	We failed to test our drinking water for the contaminant and period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Special Notice for Availability of unregulated contaminant Monitoring Data-  
Template 3-9

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**

**Availability of Monitoring Data for Unregulated Contaminants for City of Kenedy**

Our water system has sampled for a series of unregulated contaminants. Unregulated contaminants are those that don't yet have a drinking water standard set by EPA. The purpose of monitoring for these contaminants is to help EPA decide whether the contaminants should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact Johnny Rodriguez at 830-299-1774.

This notice is being sent to you by City of Kenedy, State Water System ID#: TX1280002, Date Distributed: 7/1/2024